



Collab. Ref.: 1214712.

File Ref.: 16/3/R 16/3/2/1

L Williams

KNYSNA
Municipality Munisipaliteit uMasipala
INCLUSIVE. INNOVATIVE. INSPIRED.

16 August 2022

BDE Consulting Engineers (Pty) Ltd

73 Meade Street

P O Box 1862

George

6530

E-mail Address: bde@bdeconsult.co.za

ATTENTION: MR DANIE DE VRIES

Dear Sir,

**RE: PORTION 12 OF THE FARM UITZICHT 216: ELECTRICAL LOAD CAPACITY
AVAILABILITY**

In reference to the application for the capital contribution fees submitted on the 30th May 2022 for the new development in Erf 12/216 Uitzicht.

At present, there is a closest 315kVA Miniature Substation (MS No.5) installed in Duthie Street. The maximum current load on this MS No.5 is approximately at 50kVA as illustrated on Annexure A & B.

The Municipality therefore confirms that there is adequate electrical load capacity in the MS No.5 to accommodate the required 100kVA for the aforementioned erf.

Should you have any further enquiries, please contact Lindikhaya Williams on telephone number: 044 302 6484 or via e-mail address: lwilliams@knysna.gov.za.

Yours Faithfully

MR T BIYELA

SNR ELECTRICAL & MECHANICAL MANAGER

(lw)